

Oil Wet Ramp Slip Resistance Test Certificate

Monday, 30th October 2017

Supplier: Terra Mater Hardwood Floors Pty Ltd (23-27 Rodeo Drive, Dandenong, VIC 3175)

Sample Description: 5mm RESI Vinyl Plank

Date Tested: October 2017 (Tested through FORAY Laboratories – NATA Accreditation 1231)

Test Method: AS/NZS 4586:2013 Appendix D “Slip resistance classification of new pedestrian surface materials – Oil Wet Inclining Platform Test Method” using Leipzig V73-SP shoes.

Test Data:

Sample Identification	Corrected mean overall acceptance angle result	Classification (Standards Australia Handbook 198)
5mm RESI Vinyl Plank	10°	R10




Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Nick Joy
BSc(Hons)
Consultant



Tuan Duong
B. Eng. (Chemical)
Consultant

CV171051