

Emission Test Certificate

Wednesday, 11th May 2016

Supplier: Terra Mater Hardwood Floors Pty Ltd (43 Nicholas Drive, Dandenong South, VIC 3175)

Sample Description: Terra Mater – Lakewood

Date Tested: April 2016 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: ASTM D5116 “Standard Guide for Small-Scale Environmental Chamber Determinations of Organic Emissions from Indoor Material/Products”.

Emission Data:

Green Building Council of Australia Green Star Office Design v3 IEQ-13	Terra Mater – Lakewood
Total Volatile Organic Compound Emission Rate limit <0.5 mg/m ² /hr	Total Volatile Organic Compound Emission Rate: 0.016 mg/m ² /hr
4-phenylcyclohexene Emission Rate limit <0.05 mg/m ² /hr	4-phenylcyclohexene Emission Rate: <0.004 mg/m ² /hr
Formaldehyde Emission Rate limit <0.1 mg/m ² /hr	Formaldehyde Emission Rate: 0.093 mg/m ² /hr



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Nick Joy
BSc(Hons)
Consultant



Tuan Duong
B Eng. (Chem.)
Consultant

CV160428