

# Wet Slip Test Certificate

Monday December 05<sup>th</sup>, 2016

Supplier: Terra Mater Hardwood Floors Pty Ltd (43 Nicholas Drive, Dandenong South, VIC 3175)

Sample Description: Lamwood FM-1409

Date Tested: November 2016 (Tested through FORAY Laboratories – NATA Accreditation 1231)

Test Method: AS/NZS 4586-2004 Appendix A “Slip resistance classification of new pedestrian surface materials – Wet Pendulum Test Method” using a Four S slider

Test Data:

Sample Identification	Wet floor friction result <sup>1</sup>	Classification <sup>2</sup> (Standards Australia Handbook 197)
Lamwood FM-1409	30	P2

<sup>1</sup> Six test average value

<sup>2</sup> The classifications indicate that the contribution of the floor surfaces to the risk of slipping when wet is moderate to high.



Dr. Vyt Garnys  
PhD, BSc(Hons) AIMM, ARACI, ISIAQ  
ACA, AIRAH, FMA  
Managing Director and Principal Consultant



Nick Joy  
BSc(Hons)  
Consultant



Tuan Duong  
B. Eng. (Chemical)  
Consultant

CV161129a