

# Fire & Smoke Test Certificate

Monday December 05<sup>th</sup>, 2016

Supplier: Terra Mater Hardwood Floors Pty Ltd (43 Nicholas Drive, Dandenong South, VIC 3175)

Sample Description: Lamwood FM-1409

Date Tested: November 2016

Test Method: ISO 9239-1:2010 Part 1: Reaction to Fire Tests for Floorings. Determination of the Burning Behaviour using a Radiant Heat Source.

Test Data:

<b>ISO 9239-1:2010 Part 1</b>	<b>Lamwood FM-1409</b>
<b>Critical Heat Flux/Critical Radiant Flux*</b>	5.2 kW/m <sup>2</sup>
<b>Smoke Value*</b>	5 % .min
<b>Blistering</b>	Yes
<b>Glowing</b>	Yes
<b>Smoldering</b>	Yes

\*Three test average value



Dr. Vyt Garnys  
PhD, BSc(Hons) AIMM, ARACI, ISIAQ  
ACA, AIRAH, FMA  
Managing Director and Principal Consultant



Nick Joy  
BSc(Hons)  
Consultant



Tuan Duong  
B. Eng. (Chemical)  
Consultant

CV161129a