

Emission Test Certificate

Wednesday, May 18th, 2016

Supplier: Premium Floors (7/14 Rodborough Road, French's Forest, NSW 2086)

Sample Description: Unilin 12mm Laminate Flooring

Date Tested: May 2016 (Tested by FORAY Laboratories – NATA Accreditation 1231)


Test Method: ASTM D5116 “Standard Guide for Small-Scale Environmental Chamber Determinations of Organic Emissions from Indoor Material/Products”.

Emission Data:

<p>Green Building Council of Australia Green Star Design & As Built v1.1 13.1.1</p>	<p>Unilin 12mm Laminate Flooring</p>
<p>Total Volatile Organic Compound Emission Rate limit <0.5mg/m²/hr</p>	<p>Total Volatile Organic Compound Emission Rate: 0.046 mg/m²/hr</p>
<p>4-phenylcyclohexene Emission Rate limit <0.05mg/m²/hr</p>	<p>4-phenylcyclohexene Emission Rate: <0.004 mg/m²/hr</p>
<p>Formaldehyde Emission limit <0.100 mg/m²/hr</p>	<p>Formaldehyde Emission: <0.005 mg/m²/hr</p>



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Tuan Duong
PhD, B.E. Chem.
Consultant



Nick Joy
BSc (Hons)
Consultant

CV160516