

# Emission Test Certificate

Friday, April 17<sup>th</sup>, 2015

Supplier: Australian Select Timbers Pty Ltd (61-63 Discovery Road, Dandenong, VIC 3175)

Sample Description: Hickory Impressions

Date Tested: March 2014 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: ASTM D5116 “Standard Guide for Small-Scale Environmental Chamber Determinations of Organic Emissions from Indoor Material/Products”.

Emission Data:

<b>Green Building Council of Australia Green Star Office Design v3 IEQ-13</b>	<b>Hickory Impressions</b>
Total Volatile Organic Compound Emission Rate limit <0.5mg/m <sup>2</sup> /hr	Total Volatile Organic Compound Emission Rate: 0.022mg/m <sup>2</sup> /hr
4-phenylcyclohexene Emission Rate limit <0.05mg/m <sup>2</sup> /hr	4-phenylcyclohexene Emission Rate: <0.006mg/m <sup>2</sup> /hr
Formaldehyde Emission Rate limit <0.1mg/m <sup>2</sup> /hr	Formaldehyde Emission Rate: 0.007mg/m <sup>2</sup> /hr



Dr. Vyt Garnys  
PhD, BSc(Hons) AIMM, ARACI, ISIAQ  
ACA, AIRAH, FMA  
Managing Director and Principal Consultant



Nick Joy  
BSc(Hons)  
Consultant

**CV150326**