

# Dry Slip Test Certificate

Friday November 06<sup>th</sup>, 2020

Supplier: Terra Mater Hardwood Floors Pty Ltd (PO BOX 4540 Dandenong South VIC 3175)

Sample Description: SPC Vinyl Plank

Date Tested: November 2020 (Tested through FORAY Laboratories - NATA Accreditation 1231)

Test Method: AS/NZS 4586-2013 Appendix B "Slip resistance classification of new pedestrian surface materials – Dry Floor Friction Test Method" using Slider 96

Test Data:


Sample Identification	Coefficient of Friction (COF): <sup>1</sup>	Classification <sup>2</sup> (Classification of Pedestrian Surface materials Accordance to The AS 4586 Dry Floor Friction Test)
SPC Vinyl Plank	0.65	D1

<sup>1</sup> Two test average value.

<sup>2</sup> The classification indicates that the contribution of the floor surfaces to the risk of slipping when dry is very low.



Dr. Vyt Garnys  
PhD, BSc(Hons) AIMM, ARACI, ISIAQ  
ACA, AIRAH, FMA  
Managing Director and Principal Consultant



Srikanth C. Srivatsa  
PhD (Chemistry)  
Consultant



Tuan Duong  
PhD (Chemical Engineer)  
Senior Consultant

V2010064