

Dry Slip Test Certificate

Wednesday December 11th, 2019

Supplier: Terra Matter Hardwood Floors Pty Ltd (PO Box 731, Heathmont, VIC, 3135, Australia)

Sample Description: Laminate AC4 Flooring Plank

Date Tested: October 2019 (Tested through FORAY Laboratories - NATA Accreditation 1231)

Test Method: AS/NZS 4586-2013 Appendix B "Slip resistance classification of new pedestrian surface materials – Dry Floor Friction Test Method" using Slider 96

Test Data:

Sample Identification	Coefficient of Friction (COF) ¹	Classification ² (According to the AS 4586 dry floor friction test)
Laminate AC4 Flooring Plank	0.50	D1

¹ Two test average value.

² The classification indicates that the contribution of the floor surfaces to the risk of slipping when dry is low.



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Dale Duncan
BSc (Hons)
Graduate Consultant



Tuan Duong
B.Eng. (Chemical)
Consultant

V1910010