

# AWTA PRODUCT TESTING

Australian Wool Testing Authority Ltd - trading as AWTA Product Testing  
A.B.N 43 006 014 106


1st Floor, 191 Racecourse Road, Flemington, Victoria 3031  
P.O Box 240, North Melbourne, Victoria 3051  
Phone (03) 9371 2400

## TEST REPORT

**Client :** Paxwood Pty Ltd T/A Clever Choice Design Floors  
Unit 1  
164 Adderlely Street  
West Auburn NSW 2144

**Test Number :** 24-000028  
**Issue Date :** 7/02/2024  
**Print Date :** 7/02/2024

**Sample Description** Clients Ref : "Clever Classic Vinyl 5mm"  
Vinyl flooring planks  
Colour : Timber  
End Use : Flooring  
Nominal Composition : Virgin PVC  
Nominal Mass per Unit Area/Density : 2000kg/m3  
Nominal Thickness : 5mm



314915

68623

Page 1 of 2

© Australian Wool Testing Authority Ltd  
Copyright - All Rights Reserved



Accredited for compliance with ISO/IEC 17025 - Testing  
Accreditation Numbers: 983, 985, and 1356

Samples and their identifying descriptions have been provided by the client unless otherwise stated. AWTA Ltd makes no warranty, implied or otherwise, as to the source of the tested samples. The above test results relate only to the sample or samples tested. This document shall not be reproduced except in full and shall be rendered void if amended or altered. This document, the names AWTA Product Testing and AWTA Ltd may be used in advertising providing the content and format of the advertisement have been approved by the Managing Director of AWTA Ltd.



Fiona McDonald

APPROVED SIGNATORY

MICHAEL A. JACKSON B.Sc.(Hons)  
MANAGING DIRECTOR

# AWTA PRODUCT TESTING

Australian Wool Testing Authority Ltd - trading as AWTA Product Testing  
A.B.N 43 006 014 106

1st Floor, 191 Racecourse Road, Flemington, Victoria 3031  
P.O Box 240, North Melbourne, Victoria 3051  
Phone (03) 9371 2400

## TEST REPORT

**Client :** Paxwood Pty Ltd T/A Clever Choice Design Floors  
Unit 1  
164 Adderlely Street  
West Auburn NSW 2144

**Test Number :** 24-000028  
**Issue Date :** 7/02/2024  
**Print Date :** 7/02/2024

### AS 4586-2013 Appendix A

### Slip Resistance Classification of new Pedestrian Surface Materials Wet Pendulum Test Method

Date of Testing 06-02-2024  
Operator AWTA Test Operator 14  
Test Temperature (20±5degC) 22 °C  
Specimens washed with pH neutral detergent then dried.  
Test Direction Length  
Fixed/Unfixed Unfixed  
Slider No 96 Batch No 23  
Length 1 2 3 4 5 SRV  
British Pendulum 45 43 45 44 45 44  
number  
Classification P3

Equipment: Cooper Pendulum Skid Tester Serial No: 1433-01 Calibrated 11/10/2023  
Slider prepared using P400 and 3µm lapping film.

These results apply only to the specimens tested and it is recommended that before selection of flooring or paving materials the effect of service conditions, including maintenance and wear on their slip resistance be checked.

314915

68623

Page 2 of 2

© Australian Wool Testing Authority Ltd  
Copyright - All Rights Reserved



Accredited for compliance with ISO/IEC 17025 - Testing  
Accreditation Numbers: 983, 985, and 1356

Samples and their identifying descriptions have been provided by the client unless otherwise stated. AWTA Ltd makes no warranty, implied or otherwise, as to the source of the tested samples. The above test results relate only to the sample or samples tested. This document shall not be reproduced except in full and shall be rendered void if amended or altered. This document, the names AWTA Product Testing and AWTA Ltd may be used in advertising providing the content and format of the advertisement have been approved by the Managing Director of AWTA Ltd.

